

SISTEMA SANCAD - PLANILHA DE DADOS FINAIS
SERVIÇO INTERMUNICIPAL DE ÁGUA E ESGOTO
SIMAE - CAPINZAL E OURO
REDE ESGOTO ESCADA ADELMO BIAVATI E R.

02/06/2020

Trecho	PVM	PVJ	Comp (m)	CTM (m)	CTJ (m)	CCM (m)	CCJ (m)	PRFM (m)	PRFJ (m)	Diam (mm)	Decl (m/m)	Q Real Ini (l/s)	Q Real Fim (l/s)	Veloc Ini (m/s)	Veloc Fim (m/s)	Veloc Crit (m/s)	Trativa (Pa)	H/D Ini	H/D Fim	Observ.
002-001	PV008	PV009	39.00	495.900	485.900	494.850	484.850	1.050	1.050	150	0.25641	0.040	0.068	2.06	2.06	1.70	21.01	0.09	0.09	
002-002	PV009	PV010	10.00	485.900	483.501	484.850	482.451	1.050	1.050	150	0.23990	0.050	0.086	2.01	2.01	1.71	19.96	0.09	0.09	TQ 0.093
002-003	PV010		47.00	483.501	463.900	482.358	462.957	1.143	0.943	150	0.41279	0.098	0.168	2.43	2.43	1.61	30.36	0.08	0.08	FIM
001-001	PV001	PV002	79.00	489.900	481.900	488.850	480.850	1.050	1.050	150	0.10127	0.081	0.138	1.49	1.49	1.89	10.24	0.11	0.11	
001-002	PV002	PV003	54.00	481.900	477.900	480.850	476.850	1.050	1.050	150	0.07407	0.136	0.233	1.33	1.33	1.96	8.04	0.11	0.11	
001-003	PV003	PV004	11.00	477.900	477.900	476.850	476.795	1.050	1.105	150	0.00500	0.147	0.252	0.52	0.52	2.64	1.00	0.22	0.22	TQ 0.050
001-004	PV004	PV005	80.00	477.900	473.900	476.745	472.800	1.155	1.100	150	0.04931	0.229	0.392	1.16	1.16	2.05	5.86	0.13	0.13	
001-005	PV005	PV006	47.00	473.900	471.900	472.800	470.850	1.100	1.050	150	0.04149	0.276	0.474	1.09	1.09	2.09	5.13	0.13	0.13	TQ 0.154
001-006	PV006	PV007	15.00	471.900	467.900	470.696	466.696	1.204	1.204	150	0.26667	0.292	0.501	2.09	2.09	1.69	21.66	0.08	0.08	
001-007	PV007	FIM	17.00	467.900	465.900	466.696	464.850	1.204	1.050	150	0.10859	0.309	0.531	1.52	1.52	1.87	10.81	0.10	0.10	FIM